



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302687203

NAME AND ADDRESS OF THE APPLICANT

K&N Schalterentwicklungsgesellschaft m.b.H
A-1181 Wien Schumannngasse 35~37 Austria

NAME AND ADDRESS OF THE MANUFACTURER

Kraus & Naimer Produktion GmbH
A-1181 Wien Schumannngasse 31-39 Austria

NAME AND LOCATION OF THE FACTORY

Kraus & Naimer Produktion GmbH
D-76189 Karlsruhe Wikingerstrasse 20-28 Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Switch-disconnector
KG125,KG126,KG127,KG160,KG161,KG162;See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.13,2024

Valid until: Sep.12,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





中国国家强制性产品认证证书

证书编号：2024010302687203

认证委托人名称及地址

K&N Schalterentwicklungsgesellschaft m. b. H
A-1181 Wien Schumanngasse 35~37 Austria

生产者名称及地址

Kraus & Naimer Produktion GmbH
A-1181 Wien Schumanngasse 31-39 Austria

生产企业名称及地址

Kraus & Naimer Produktion GmbH
D-76189 Karlsruhe Wikingenstrasse 20-28 Germany

产品名称和系列、型号、规格

隔离开关

KG125,KG126,KG127,KG160,KG161,KG162;详见附页

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求，特发此证。

发证日期：2024年09月13日 有效期至：2029年09月12日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010302687203

证书附页：第 1 页 共 2 页

KG125,KG126,KG127,KG160,KG161,KG162

Uimp: 8kV;

Ui: 1000V;

Ith: 125A(KG125, KG126, KG127);160A(KG160,KG161,KG162);

Ue/Ie:

AC-21A:

220~240V/125A(KG125,KG126,KG127),220~240V/160A(KG160,KG161,KG162);

380~440V/125A(KG125,KG126,KG127),380~440V/160A(KG160,KG161,KG162);

660~690V/125A(KG125,KG126,KG127),660~690V/160A(KG160,KG161,KG162);

AC-22A:

220~240V/125A(KG125,KG126,KG127),220~240V/160A(KG160,KG161,KG162);

380~440V/125A(KG125,KG126,KG127),380~440V/160A(KG160,KG161,KG162);

660~690V/125A(KG125,KG126,KG127),660~690V/160A(KG160,KG161,KG162);

AC-23A:

220~240V/96A(KG125,KG126,KG127),220~240V/103A(KG160,KG161,KG162);

380~440V/80A(KG125,KG126,KG127),380~440V/105A(KG160,KG161,KG162);

AC-3: 220~240V/72A(KG125,KG126, KG127),220~240V/103A(KG160, KG161, KG162);

380~440V/66A(KG125,KG126, KG127),380~440V/85A(KG160, KG161, KG162);

Icw:2.5kA/1s(KG125,KG126, KG127) ; 3kA/1s(KG160, KG161, KG162);

Icm(峰值):6kA (KG125, KG126, KG127) ; 7.5kA (KG160, KG161, KG162);

Iq:30kA;

使用类别：AC-21A,AC-22A,AC-23A,AC-3;

极数：3P,4P,6P,8P

适用频率：50/60Hz

型号解释：

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号：2024010302687203

证书附页：第 2 页 共 2 页

开关型号
KG 125

功能 及 组成代号
T203 / SGZ001

安装方式
VE

E 用螺钉面板固定
VE 底座/导轨固定式

组成/档案代号,登记客户要求。型号含字母及数字共6位, AA0001 - ZZ9999

例: PCZ001 客户要求带120mm延长轴。
SGZ006 客户要求带红色把手,黄色框架。
US6084 客户要求不带把手。

极数+公能号,

- K300/T103/T203/T303 -- 通断型3极
- K400/T104/T204/T304 --- 通断型4极
- K600/T106/T206/T306 --- 通断型6极
- K800/T108/T208/T308 --- 通断型8极
- K900/T903 -- 双投转换3极
- K950/T904 --- 双投转换4极

系列型号,

- KG125, Iu/Ith=125A,接线端子结构: 柱式夹紧
 - KG126, Iu/Ith=125A,接线端子结构: 接线片式夹紧
 - KG127, Iu/Ith=125A,接线端子结构: 混合,柱式和接线片夹紧
 - KG160, Iu/Ith=160A,接线端子结构: 柱式夹紧
 - KG161, Iu/Ith=160A,接线端子结构: 接线片式夹紧
 - KG162, Iu/Ith=160A,接线端子结构: 混合,柱式和接线片夹紧
- 壳架等级K2/安装尺寸S2

本页为证书附页,应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司