



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302687206

NAME AND ADDRESS OF THE APPLICANT

K&N Schalterentwicklungsgesellschaft m.b.H
A-1181 Wien Schumanngasse 35~37 Austria

NAME AND ADDRESS OF THE MANUFACTURER

Kraus & Naimer Produktion GmbH
A-1181 Wien Schumanngasse 31-39 Austria

NAME AND LOCATION OF THE FACTORY

Kraus & Naimer Produktion GmbH
D-76189 Karlsruhe Wikingerstrasse 20-28 Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Switch-disconnector
KG250, KG251, KG252, KG315, KG316, KG317;See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.13,2024

Valid until: Sep.12,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





中国国家强制性产品认证证书

证书编号：2024010302687206

认证委托人名称及地址

K&N Schalterentwicklungsgesellschaft m. b. H
A-1181 Wien Schumanngasse 35~37 Austria

生产者名称及地址

Kraus & Naimer Produktion GmbH
A-1181 Wien Schumanngasse 31-39 Austria

生产企业名称及地址

Kraus & Naimer Produktion GmbH
D-76189 Karlsruhe Wikingenstrasse 20-28 Germany

产品名称和系列、型号、规格

隔离开关

KG250, KG251, KG252, KG315, KG316, KG317; 详见附页

产品标准和技术要求

GB/T 14048.3-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2024年09月13日 有效期至：2029年09月12日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010302687206

证书附页：第 1 页 共 2 页

KG250, KG251, KG252, KG315, KG316, KG317

Uimp: 8kV;

Ui: 1000V;

Ith: 250A (KG250, KG251, KG252), 315A (KG315, KG316, KG317);

Ue/Ie:

AC-21A:

220~240V/250A(KG250,KG251,KG252),220~240V/315A(KG315,KG316,KG317),

380~440V/250A(KG250,KG251,KG252),380~440V/315A(KG315,KG316,KG317),

660~690V/250A(KG250,KG251,KG252),660~690V/315A(KG315,KG316,KG317);

AC-22A:

220~240V/200A(KG250,KG251,KG252),220~240V/250A(KG315,KG316,KG317),

380~440V/200A(KG250,KG251,KG252),380~440V/250A(KG315,KG316,KG317),

660~690V/125A(KG250,KG251,KG252),660~690V/140A(KG315,KG316,KG317);

AC-23A:

220~240V/126A(KG250,KG251,KG252),220~240V/182A(KG315,KG316,KG317),

380~440V/170A(KG250,KG251,KG252),380~440V/205A(KG315,KG316,KG317),

660~690V/50A(KG250,KG251,KG252),660~690V/50A(KG315,KG316,KG317);

AC-3:

220~240V/126A(KG250,KG251,KG252),220~240V/147A(KG315,KG316,KG317),

380~440V/105A(KG250,KG251,KG252),380~440V/138A(KG315,KG316,KG317),

660~690V/45A(KG250,KG251,KG252),660~690V/50A(KG315,KG316,KG317);

Icw: 4.6kA/1s (KG250, KG251, KG252), 5.8kA/1s (KG315, KG316, KG317);

Icm(峰值): 8kA (KG250,KG251, KG252), 9kA (KG315, KG316, KG317);

Iq: 30kA (KG250,KG251, KG252), 15kA (KG315,KG316,KG317);

使用类别: AC-21A、AC-22A、AC-23A、AC-3;

极数: 3P,4P;

适用频率: 50/60Hz

型号解释:

本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE


中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号：2024010302687206

证书附页：第 2 页 共 2 页



本页为证书附页，应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司